City of West University Place Inspection Card

	Address
	Date
	N CALL 713-662-5805 BEFORE 7:45 AM THE DAY PECTION IS DESIRED.
Building	Pool/Spa
Plumbing	Driveway
Electrical	Sidewalk
Mechanical	Remodel
Other	
THIS PERMIT CARD SHALL BE POS FROM THE STREET AND REMAI A	& 2011 National Electrical Code both with local amendments TTED INSIDE THE FRONT WINDOW AND BE VISIBLE IN POSTED UNTIL ALL WORK IS COMPLETE AND PPROVED BY THE WEST UNIVERSITY PLACE
Issued By:	Date:
EXPIRES:	4-13-16 ЈМН

INSPECTION TYPE	DATE	APPROVED BY	COMMENTS
PIER HOLES			3 RD PARTY & City of West U. Insp.
PLB. INGROUND			Water to remain until concrete placed
FOUNDATION STEEL			Form Survey Required the day before
STOP			NOTE: Engineer Foundation Certificate
All above must be approved to		STOP	required for piers & foundations before any
continue!!!			construction begins
PLUMBING TOPOUT			Includes a gas rough pressure test 25 PSI+
MECHANICAL ROUGH-IN			
ELECTRICAL ROUGH-IN			
Above Must Be APPROVED Before			
Inspecting Frame!!!			
WIND SPEED CLIPS & STRAPS			
SHEAR WALL & NAIL PATTERN		NO INSPECTION	
FRAMING			
BOLTING & WELDING	>>>>>>	>>>>>>>	Certified Third Party by Builder, compliance report
BORTH O W WEEDING			to city.
Do Not Cover Until All Above Have		STOP	Note: Engineer Framing & Height
Been Approved!!!!!!!!			Certificate required prior to cover.
ENERGY CODE ROUGH-IN	>>>>>>	>>>>>>>	THIRD PARTY INSPECTION BY
			BUILDER
BRICK TIE			24" on center each way
STUCCO LATHE			EJ's @144sf & CJ's all opening corners
Sheetrock 5/8" Type X		NO INSPECTION	All Areas
Sheetreek e/o Type II			111111111111111111111111111111111111111
Shower Pan			Min. 2" curb, extend liner 3" above curb
Cement/Fiber-Cement/Glass Mat			Tub & Shower Areas R702.4.2
Roofdeck, felt, <u>flashing</u> , shingles,			R905.2.8.4 Sidewall flashing.
metal, tile, slate		NO INSPECTION	Flashing against a vertical sidewall shall be by the
		NO INSI BETTON	step-flashing method, ONLY
ConcretePaving / Flatwork			Reinforcement required in all
Public/Private D/W, S/W, Patios			· · · · · · · · · · · · · · · · · · ·
PLUMBING -GTO			Final test 15# gage with 10 PSI test
ELECTRICAL—TCI-			
TREE Disposition Final			City's Urban Forester to inspect
******FINALS*****		*****FINALS*****	
BUILDING			A Final Survey & TOPO is required
PLUMBING			the day before final inspection
ELECTRICAL			Along with other documents
HVAC			
LANDSCAPE			
ADDRESS POSTED	1. Within 24	principal entrance to the building	2. On the door of the principal entrance in a
4" high ½" stroke	or in part) of the	at a height of at least five feet above standard base level; or	color in sharp and direct contrast with the background.
	or in part) or the	acove sumand base level, of	ouenground.
Energy Code Compliance	>>>>>>	>>>>>>>	3 RD PARTY INSPECTION/BUILDER
Energy Code Comphance	********		J TIMIT INSTECTION BUILDEN
CHAINIMING DOOL (CDA			
SWIMMING POOL/SPA			
Steel Pool/Spa including PLBG			**All main drains shall be filled with
Deck			water to 6" above ground level**
Plumbing Gas Line & Test			50 PSI test on piping & AVB on fill line
			Final test 15# gage with 10 PSI test
Electrical Underground			
Bonding ***			*** Bond 360 deg. Minimum 4 places
*****Enclosure & Alarm****	>>>>>>	>>>>>>>	To be inspected before water is in pool.
FINALSPool/Spa			
Electrical			
Plumbing			
Anti-Entrapment Compliance			Main drains 3' apart w/ code cover
Atmospheric vacuum relief			Per AG106.3
system required		<u> </u>	
y			